

# README

2022-11-08

There are two EtherCAT XML file versions available that can be used by a master when configuring the Fieldbus:

- Hilscher COMX 51XX RE ECS V4.2.X IPG ScannerFieldbusInterface.xml
- Hilscher COMX 51XX RE ECS V4.6.X IPG ScannerFieldbusInterface.xml

The V4.2.X variant is generally compatible with most PLC masters. The V4.6.X variant is included for compatibility when configuring Fieldbus with Hilscher PLC masters.